

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/29/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155177		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 04 B. WING _____		(X3) DATE SURVEY COMPLETED 09/22/2011	
NAME OF PROVIDER OR SUPPLIER WESTMINSTER VILLAGE - WEST LAFAYETTE				STREET ADDRESS, CITY, STATE, ZIP CODE 2741 NORTH SALISBURY ST WEST LAFAYETTE, IN 47906			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Environmental Preoccupancy Survey for the addition of 10 Title 18 beds to rooms 1, 9, 13, 19, 20, 22, 24, 25, 26 and 27 on the Courtyard unit was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 09/22/11</p> <p>Facility Number: 000093 Provider Number: 155177 AIM Number: NA</p> <p>Surveyor: Bridget Brown, Medical Surveyor, Life Safety Code Specialist</p> <p>At this Life Safety Code and Environmental Preoccupancy Survey, Westminster Village-West Lafayette was found to be in compliance with the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 19, Existing Health Care Occupancies and with 410 IAC 16.2-3.1-19 Environment and Physical Standards of Indiana's Health Facilities Rules for Comprehensive care facilities.</p> <p>The facility was determined to be of Type III (211) construction. The facility was fully sprinklered, has a fire alarm system with smoke detection in the corridors, resident rooms and spaces open to the corridors. The facility has the capacity for 58 and had a census of 42 residents.</p> <p>Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 09/26/2011.</p>			K 000			
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code and Environmental</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/29/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155177		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 04 B. WING _____		(X3) DATE SURVEY COMPLETED 09/22/2011	
NAME OF PROVIDER OR SUPPLIER WESTMINSTER VILLAGE - WEST LAFAYETTE				STREET ADDRESS, CITY, STATE, ZIP CODE 2741 NORTH SALISBURY ST WEST LAFAYETTE, IN 47906			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Preoccupancy Survey for the addition of 31 Title 18 beds to rooms A1-A21 on the newly constructed Terrace unit was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 09/22/11</p> <p>Facility Number: 000093 Provider Number: 155177 AIM Number: NA</p> <p>Surveyor: Bridget Brown, Medical Surveyor, Life Safety Code Specialist</p> <p>At this Life Safety Code and Environmental Preoccupancy Survey, Westminster Village-West Lafayette was found to be in compliance with the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) Chapter 18, New Health Care Occupancies and with 410 IAC 16.2-3.1-19 Environment and Physical Standards of Indiana's Health Facilities Rules for Comprehensive care facilities.</p> <p>The facility was determined to be of Type III (211) construction. The facility was fully sprinklered, has a fire alarm system with smoke detection in the corridors, resident rooms and spaces open to the corridors. The facility has the capacity for 58 and had a census of 42 residents. Beds in the new addition were unoccupied.</p> <p>Quality Review by Lex Brashear, Life Safety Code Specialist-Medical Surveyor on 09/26/2011.</p>			K 000			